

Company Details		Property Inspected and Serviced	Customer Details
Company name: Ian Tate Electricals Phone: 07774 639416 Contractor name: Ian Tate	29 Moor Close Road Queensbury Bradford West Yorkshire BD13 2EA	IMS Care Ltd 66 Deighton Road Huddersfield West Yorkshire HD21LS	IMS Care Ltd 66 Deighton Road Huddersfield West Yorkshire HD21LS

System Details							
Panel Manufacturer	C-Tec			Protocol	Open		
Monitoring Info	N/A			Service Type	Yearly		
System Category	PD1	Type of System	A	Total number of devices	12	Number of devices serviced	12

Schedule Of Items Serviced			
Are MCPs suitably sited?	Pass	Are MCPs visible?	Pass
Are all final exits covered?	Pass	Are all auto-detectors suitable for location?	Pass
Are auto-detectors suitably sited?	Pass	Auto-detectors are clear of >500mm?	Pass
New devices are suitable for new build?	N/A	Have all faults been recorded by site?	Pass
Have recorded faults been attended to?	Pass	Has the rate of false alarms been recorded?	Pass

Schedule of Items Tested			
Operation of fire alarm devices?	Pass	Do panel LEDs and buttons function correctly?	Pass
Have the outputs been tested?	Pass	Have panel manufacturer checks been performed?	Pass
Fault indicators and simulation tested?	Pass	Device tested from each circuit?	Pass
Signal received at monitoring station?	N/A	Fault signal received at the monitoring station?	N/A
Will printer paper last until the next service?	N/A	Does the printer operate and print correctly?	N/A
Do alarms operate with batteries disconnected?	Pass	Battery calculation for correct battery size?	Pass
Number of false alarms	1 alarms per 1 equates to 100% over a 12 month period.		

Extent of Liability			
The extent of liability of the signatory is limited to the system described below			
Extent of system covered by this certificate		All fire alarm system	
Variations from the recommendations of BS 5839-6:2019, Clause 26 for periodic or annual inspection and test (as applicable)			
1		2	

Extent of Liability

Variations from the recommendations of BS 5839-6:2019, Clause 26 for periodic or annual inspection and test (as applicable)

3		4	
5		6	
7		8	
9		10	

The following work/action is considered necessary

1		2	
3		4	
5		6	
7		8	

Certification of Servicing

I/we being the competent person(s) responsible (as indicated by my/our signatures below) for the servicing of the fire alarm system, the particulars of which are set out above, certify that the said work for which I/we have been responsible complies, to the best of my/our knowledge and belief, with the recommendations of BS 5839-6:2019, Clause 26, except for the variations, if any, stated in this certificate.

For and on behalf of	Ian Tate Electricals 29 Moor Close Road, Queensbury, Bradford, West Yorkshire, BD13 2EA		
Name	Ian Tate	Signature	
Position	Qualified Supervisor		
Date	29/01/2026		